

**Drinking Water Quality and Compliance  
for Resort Village of Manitou Beach**  
2024 Annual Notice to Consumers

**Introduction**

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the Resort Village of Manitou Beach water quality and sample submission compliance record for the January 1, 2024 to December 31, 2024 time period. This report was completed on January 7, 2025. Readers should refer to Water Security Agency's [Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html) for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).

**Water Quality Standards**

**Bacteriological Quality**

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	24	25	0
E. coli	0 Organisms/100 mL	24	25	0
Background Bacteria	Less than 200/100 mL	24	25	0

**Water Disinfection –**

**Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples**

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.52 – 1.08	0.50 – 0.99	24	25	100 %

**Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-  
From Water Treatment Plant Records**

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.41 – 1.00	364	0

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

**Turbidity – From Water Treatment Plant Records**

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1.0	0.07 – 0.24	0	0.35	366	364

**Chemical – Health Category**

All waterworks serving less than 5000 persons are required to submit water samples for WSA's Chemical Health category once every 2 years (*unless otherwise stated in waterworks operating permit*). The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.



**Saskatchewan  
Ministry of  
Environment**



The last sample for Chemical Health analysis was submitted on January 24, 2023. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	Limit MAC (mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit	
Arsenic	0.010		0.0026 mg/L	0	* Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.
Barium	1.0		<0.0007 mg/L	0	
Boron		5.0	0.35 mg/L	0	
Cadmium	0.005		<0.00001 mg/L	0	
Chromium	0.05		<0.0005 mg/L	0	
Fluoride (avg*)	1.5		<0.01 mg/L	0	
Lead	0.01		<0.0002 mg/L	0	
Nitrate (avg.*)	45.0		<0.04 mg/L	0	
Selenium	0.01		<0.0002 mg/L	0	
Uranium	0.02		<0.0001 mg/L	0	

### General Chemical

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (average)	# Samples Required	# Samples Submitted
Alkalinity	500	37 mg/L CaCO <sub>3</sub>	1	1
Bicarbonate	No Objective	45 mg/L	1	1
Calcium	No Objective	0.2 mg/L	1	1
Carbonate	No Objective	<1 mg/L	1	1
Chloride	250	4.9 mg/L	1	1
Conductivity	No Objective	88 µs/cm	1	1
Hardness	800	<1 mg/L CaCO <sub>3</sub>	1	1
Magnesium	200	<0.1 mg/L	1	1
pH	No Objective	7.42	1	1
Sodium	300	19 mg/L	1	1
Sulphate	500	1.6 mg/L	1	1
Total dissolved Solids	1500	49 mg/L	1	1

All waterworks serving less than 5000 persons are required to submit water samples for WSA's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required by December 31, 2024 and submitted on January 22, 2024. Sample results indicated that there were no exceedances of the provincial aesthetic objectives for the General Chemical

\*Objectives apply to certain characteristics of substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazard. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

### **More information on water quality and sample submission performance may be obtained from:**

Resort Village of Manitou Beach  
701 Lakeview Avenue  
Manitou Beach SK, S0K 4T1  
306-946-2017  
[planning@manitoubeach.ca](mailto:planning@manitoubeach.ca)



**Saskatchewan  
Ministry of  
Environment**

